

**RULES FOR ELECTRIC SERVICE
RULE 8 – MEASUREMENT OF SERVICE**

A. LOCATION AND METHOD OF MEASUREMENT

(1) The customer provides free of expense to Company, at a location designated by Company, a suitable place for the Company meters and meter-related equipment, in accordance with REMSI, which is readily accessible to Company employees.

(2) The Company installs and maintains the metering equipment, unless otherwise allowed by the Commission. Where energy is metered at a point other than the point of delivery or at a voltage other than the supply voltage, readings of the meters and meter-related equipment are corrected to conform to measurement at the point of delivery and voltage supply.

B. METER INSTALLATIONS

Service at each point of delivery is metered through one or more meters as required by the applicable rate schedules. Measurements from metering equipment for separate points of delivery are never combined for billing purposes except temporarily pending completion of necessary changes in Company's facilities. The Company will relocate a meter upon request from a customer, provided that the customer agrees to pay the fully allocated cost for the relocation.

C. UNMETERED SERVICE

The Company, at its option, may determine kilowatt hours and billing demands by computation instead of by measurement for installations having a fixed load or demand value controlled to operate for a definite number of hours during a billing period. An electric service contract is required for billing this unmetered service.

D. METER TESTING

The testing and adjustment of meters are made in accordance with any applicable law and any regulation. The Company may require customers to pay a fee of \$35.00 for a meter test.

E. DETERMINATION OF DEMAND

(1) The fractional part of the demand billing unit specified in the rate schedule in excess of the minimum is taken as a whole when equal to one-half or more, otherwise, the fractional part is disregarded.

(2) Where the rate schedule provides that the demand is determined by quantities supplied during two or more periods of use, not more than one such period is taken from any one day's measurements that apply to such determination.

(3) Where the charges are based on a connected load, the customer's connected load is determined by inspection whenever Company deems necessary. Company will estimate the connected load of any customer who does not permit Company's representative to make such inspection.

RULE 8 – MEASUREMENT OF SERVICE (CONTINUED)

(4) The Company’s electric meters record average demand every 15 minutes or hourly and resets the register to zero after each monthly billing cycle. The determination of demand excludes power factor correction.

F. DEMAND INFORMATION

(1) When the customer desires to install electric load control equipment or obtain meter transmitted energy data, the Company will install the appropriate meter and connection tie box (hereinafter called “Demand Information System”) at no cost to the customer. REMSI provides the wiring diagram and identifies Company and Customer responsibilities.

(2) The Company will not be held responsible for interruption to the Demand Information System due to blown fuses, failure, or any malfunction of Customer’s Equipment. In addition, the Company reserves the right to interrupt the supply of electric demand information to perform meter tests or maintenance procedures and, in so doing, assumes no responsibility for the effects on the Customer’s operation or equipment.

(3) If at any time, in the Company’s sole judgment, based upon existing facts and circumstances, the supply of electric demand information through the Demand Information System becomes detrimental to reliable metering, the Company shall have the right to disconnect the Demand Information System from its metering facilities immediately upon advance notice to the customer and without liability.

(4) Under no circumstances shall the Customer modify, adjust or interrupt the operation of the Company’s facilities. In addition, the Company’s billing meter installation shall, in all instances, govern when establishing Customer’s energy and demand record for billing purposes.