

RULES FOR ELECTRIC METER & SERVICE INSTALLATIONS



Table 1

Distribution Block Connectors when used for Service Drop connections to service entrance conductors shall be covered to avoid inadvertent contact. Except the neutral connection of service cable assemblies may be bare.

Approved Connector List for Sketch #49

Insulated Type - 1 (I-1) HOMAC - RXM Series POLARIS IPLMD (C) UTILCO-PSA-4-750-SS
Insulated Type - 2 (I-2) HUBBELL GU-5022 POLARIS IPLMD (C)
Bare Type - 1 (B-1) HOMAC - ABT Series UTILCO-USG-2 Series
Bare Type - 2 (B-2) UTILCO - PSA Series UTILCO/ILSCO - PSA Series
Pre-Assembled BURNDY GOULD - SHAWMUT UTILCO/ILSCO - PDB Series

(C) Indicates Change

02/2016